

Dynamics of Type-3 Wind Turbine Generator Models

Ian A. Hiskens, *Fellow, IEEE*

Abstract—The influence of wind turbine generators (WTGs) on power system dynamic performance is becoming increasingly important as wind generation grows. The dynamic behavior of WTGs should therefore be thoroughly understood. The paper analyzes dynamic models of type-3 WTGs, and in particular the WECC generic model. The behavior of such models is governed by interactions between the continuous dynamics of state variables, and discrete events associated with limits. It is shown that these interactions can be quite complex, and may lead to switching deadlock that prevents continuation of the trajectory. Switching hysteresis is proposed for eliminating deadlock situations. Various type-3 WTG models include control blocks that duplicate integrators. It is shown that this leads to non-uniqueness in the conditions governing steady-state, and may result in pre- and post-disturbance equilibria not coinciding. It also gives rise to a zero eigenvalue in the linearized WTG model.

Index Terms—Hybrid dynamical systems, singular systems, small disturbance analysis, switching deadlock, wind turbine generator modeling.

I. INTRODUCTION

THE dynamic behavior of wind turbine generators (WTGs) is quite different to that of synchronous generators. It is to be expected, therefore, that the dynamic performance of power systems may change as traditional generation is displaced by ever-increasing numbers of WTGs. Numerous studies have investigated this issue, and have drawn various conclusions [1]–[5]. This current paper does not address the system-wide implications of large-scale wind generation *per se*. Rather, it focuses on the dynamic modeling of WTGs. In particular, the modeling of type-3 WTGs is considered, as they are currently the dominant technology for new wind farm developments. Such WTGs are also known as doubly fed induction generators (DFIGs) or doubly fed asynchronous generators.

The accuracy of system studies depends on the fidelity of the underlying models [6], [7]. Accordingly, the modeling of type-3 WTGs has received considerable attention; see [1], [8]–[12], and references therein. Turbine manufacturers routinely develop and maintain accurate models for their products, though disclosure of those models is highly restricted. In some cases, they have released models that describe functionally similar behavior [13], though such practice is not common. Regional reliability

organizations need to exchange models and data that are relevant to their jurisdiction. This has motivated the development of generic models that can be used to capture the functional characteristics of a wide variety of type-3 WTGs [14]–[16].

The electrical characteristics of type-3 WTGs are governed by interactions between a wound-rotor induction machine and a back-to-back inverter. The inverter excites the rotor of the induction machine with a variable AC source. This provides control of the rotor flux frequency, enabling the rotor shaft frequency to optimally track wind speed [17]. The inverter response time is very fast relative to electromechanical time constants. As a result, the natural dynamics of the induction machine are largely masked from the power system. The dynamic behavior of a type-3 WTG, as seen from the grid, is therefore dominated by controller response rather than physical characteristics. This is in marked contrast to traditional synchronous generators, where behavior is governed by device physics.

Controller limits play an integral role in the dynamic performance of type-3 WTGs, with further details provided in Section II. Intrinsic interactions between continuous dynamics and limit-induced discrete events suggest that type-3 WTGs may be classified as hybrid dynamical systems [18]–[20]. It will be shown in Section III that the resulting hybrid dynamics may, in fact, lead to unusual forms of behavior. The hybrid nature of dynamics also has implications for small disturbance studies.

The studies presented in this paper focus on the WECC generic type-3 model [15], [16]. This model has been chosen because it is widely used, and is indicative of type-3 models that are generally available. All such generic models are an approximation of the actual dynamics exhibited by a WTG. It is important, though, that such approximations reflect the physical reality of the modeled device.

The paper is organized as follows. Section II provides a thorough description of the WECC type-3 WTG model. It is shown in Section III that non-windup limiter models may cause switching deadlock, preventing trajectory continuation in the usual sense. Alternative model formulations that circumvent such behavior are discussed. Section IV shows that the model allows multiple equilibria, and discusses the implications. Small disturbance analysis is considered in Section V, and conclusions are presented in Section VI.

II. TYPE-3 WTG MODEL

The WECC type-3 wind turbine generator model is defined in [15] and [16]. The complete WTG model is divided into four functional blocks, as indicated in Fig. 1. This paper is primarily concerned with the dynamic interactions of the converter control model WT3E, the pitch control model WT3P, and the wind

Manuscript received February 09, 2011; revised May 20, 2011; accepted June 13, 2011. Date of publication September 06, 2011; date of current version January 20, 2012. This work was supported by the Department of Energy through award DE-EE0001382, the National Science Foundation through grant ECS-0725710, and NREL. Paper no. TPWRS-00107-2011.

The author is with the University of Michigan, Ann Arbor, MI 48105 USA (e-mail: hiskens@umich.edu).

Color versions of one or more of the figures in this paper are available online at <http://ieeexplore.ieee.org>.

Digital Object Identifier 10.1109/TPWRS.2011.2161347




Fig. 1. Type-3 WTG dynamic model connectivity, from [15] and [16].




Fig. 2. Converter control model WT3E, from [15] and [16].

turbine model WT3T. Accordingly, only those models are described in detail in the following analysis.

A. Converter Control Model WT3E

The converter control model is composed of separate active and reactive power control functions. Reactive power control is very fast, due to the power electronic converter. This paper focuses on the slower dynamics associated with interactions between active power (torque) control, pitch control, and the coupling through the shaft dynamics. Accordingly, only the active power model, which is shown in Fig. 2, will be discussed. Again, full details of the reactive power controller are provided in [15] and [16].

The non-windup (anti-windup) limits on the PI block in the center of Fig. 2 are driven by the non-windup P_{\max}/P_{\min} limits associated with the P_{ord} lag block. The model documentation stipulates that:

- 1) If P_{ord} is on its P_{\max} limit and ω_{err} (the input to the PI block) is positive, then the K_{itrq} -integrator is blocked, i.e., the state T_{ω} of that integrator is frozen.
- 2) If P_{ord} is on the P_{\min} limit and ω_{err} is negative, then the K_{itrq} -integrator state is frozen.

This form of non-windup limit is unusual, though a precedence can be found in Annex E.5 of IEEE Standard 421.5-2005 [21]. It will be shown in Section III that such non-windup logic can result in switching deadlock [22].

Assembling all the equations for the model gives

$$\frac{d\omega_{\text{ref}}}{dt} = \frac{1}{T_{\text{sp}}} (f(P_{\text{gen}}) - \omega_{\text{ref}}) \quad (1)$$

$$\frac{dT_{\omega}}{dt} = K_{\text{itrq}} (\omega - \omega_{\text{ref}}) \times y_{fr} \quad (2)$$




Fig. 3. Pitch control model WT3P, from [15] and [16].

$$\frac{dP_{\text{ord}}}{dt} = P_{\text{ord,rtlm}} \times y_{mx,sw} \times y_{mn,msw} \quad (3)$$

$$P_{\text{ord,rate}} = \frac{1}{T_{\text{pc}}} (\omega (T_{\omega} + K_{\text{ptrq}} (\omega - \omega_{\text{ref}})) - P_{\text{ord}}) \quad (4)$$

together with switched equations that are fully described in [23].¹ The auxiliary variables required to implement limits and switching action are

$P_{\text{ord,rtlm}}$: the rate-limited version of $P_{\text{ord,rate}}$;

$y_{mx,sw}$: equals 0 when $P_{\text{ord}} = P_{\max}$ and 1 otherwise;

$y_{mn,sw}$: equals 0 when $P_{\text{ord}} = P_{\min}$ and 1 otherwise;

y_{fr} : equals 0 when the conditions for blocking the

K_{itrq} -integrator are satisfied and 1 otherwise.

The function $f(P_{\text{gen}})$ is typically modeled as a piece-wise affine function. WECC default parameters are provided in the Appendix.

B. Pitch Control Model WT3P

The pitch control model WT3P is shown in Fig. 3. Of particular interest is the implementation of the non-windup limiter on the pitch angle θ . As stated in the model documentation:

“The Pitch Control and Pitch Compensation integrators are non-windup integrators as a function of the pitch, i.e., the inputs of these integrators are set to zero when the pitch is in limits (PI_{\max} or PI_{\min}) and the integrator input tends to force the pitch command further against its limit.”

To illustrate, consider the case where θ is on its lower limit PI_{\min} . A negative input to the pitch-control integrator would cause the corresponding state x_p to reduce, which in turn would force θ further against its PI_{\min} limit. To prevent that wind-up effect, the integrator is blocked under such conditions. Similarly, the pitch-compensation integrator is blocked when its input is negative. When θ is on its upper limit PI_{\max} , blocking of the up-stream integrators occurs when their respective inputs are positive.

This blocking philosophy is the same as that employed in the converter control model WT3E, as discussed in Section II-A. It should again be mentioned that such blocking can result in switching deadlock. This will be explored in Section III.

The equations describing the WT3P model can be written:

$$\frac{dx_p}{dt} = K_{\text{ip}} (\omega - \omega_{\text{ref}}) \times y_{fr,1} \quad (5)$$

¹Space limitations prevent inclusion of these coupled equations.




Fig. 4. Single-mass turbine model WT3T, from [15] and [16].

$$\frac{dx_c}{dt} = K_{ic}(P_{ord} - P_{set}) \times y_{fr,2} \times y_{sw} \quad (6)$$

$$\frac{d\theta}{dt} = \theta_{rtlm} \times y_{mx,sw} \times y_{mn,sw} \quad (7)$$

$$\theta_{rate} = \frac{1}{T_{PI}}(\theta_{cmd} - \theta) \quad (8)$$

$$\theta_{cmd} = x_p + x_c + K_{pp}(\omega - \omega_{ref}) + K_{pc}(P_{ord} - P_{set}) \quad (9)$$

along with switched equations that are fully documented in [23]. In this case, the auxiliary variables required to implement limits and switching action are

- θ_{rtlm} : the rate-limited version of θ_{rate} ;
- $y_{mx,sw}$: equals 0 when $\theta = PI_{max}$ and 1 otherwise;
- $y_{mn,sw}$: equals 0 when $\theta = PI_{min}$ and 1 otherwise;
- y_{sw} : equals 0 when $x_c = 0$ and 1 otherwise;
- $y_{fr,1}$: equals 0 when the conditions for blocking the pitch control integrator are satisfied and 1 otherwise;
- $y_{fr,2}$: equals 0 when the conditions for blocking the pitch compensation integrator are satisfied and 1 otherwise.

C. Wind Turbine Model WT3T

The single-mass wind turbine model WT3T from [15] and [16] is shown in Fig. 4. A two-mass model is also provided in [15] and [16], but the single-mass model suffices for the discussions in this paper. The model consists of two parts, 1) a simplified model of the aerodynamic relationship between blade pitch θ and mechanical power P_{mech} , and 2) a model of the shaft dynamics. The damping constant D is always zero, so the single-mass WT3T model can be described by

$$\frac{d\omega}{dt} = \frac{1}{2H\omega}(P_{mech} - P_{gen}) \quad (10)$$

$$P_{mech} = P_{mo} - K_{aero}\theta(\theta - \theta_o). \quad (11)$$

D. Hybrid System Model

It is clear from the involvement of the switched equations in (1)–(11) that the WTG model is composed of:

- 1) differential and algebraic equations that describe continuous behavior of the associated states; and
- 2) discrete events that introduce nonsmooth behavior through switching actions.

Models that involve such interactions between continuous dynamics and discrete events have become known as hybrid dynamical systems [18]–[20]. The discrete events introduce rich

forms of behavior that are not exhibited by smooth systems described by differential (and possibly coupled algebraic) equations. In fact, it will be shown in Section III that both the WT3E and WT3P models are susceptible to switching deadlock, where a discrete state should simultaneously take two different values. This situation is impossible, of course; the trajectory is not defined (in the usual sense) beyond such an impasse.

The WTG model, described by (1)–(11) together with the coupled switched equations, has been formulated according to the differential-algebraic impulsive switched (DAIS) structure presented in [20] and [24]. A subtle (but technically important) modification was required however. In the original DAIS definition, switched algebraic equations had the form

$$0 = \begin{cases} g^+(x, y), & y_s > 0 \\ g^-(x, y), & y_s < 0 \end{cases}$$

where behavior is undefined if the trigger variable y_s remains at zero. In the case of a WTG though, it is quite common for the pitch angle θ to be initialized at the switching condition associated with its lower limit PI_{min} . To cater for that (and similar) situations, the DAIS definition has been altered to allow the trigger variable y_s to remain at zero, giving the slightly modified switching description

$$0 = \begin{cases} g^+(x, y), & y_s \geq 0 \\ g^-(x, y), & y_s < 0. \end{cases}$$

In the case of the non-windup limits within the WTG model, it has been arbitrarily decided that the integrator should remain active when its state lies at the switching point, i.e., when the trigger variable $y_s = 0$. The integrator only becomes blocked when the input seeks to force the state across the limit, resulting in $y_s < 0$.

Technical issues arise when an equilibrium point coincides with a switching condition $y_s = 0$. If the equilibrium is asymptotically stable, then generically, as the trajectory approaches the equilibrium point, the time between subsequent switching events will progressively diminish. In the limit, switching will (theoretically) become infinitely fast. Also, linearization about the equilibrium point is not defined, as the vector field is not smooth. Consequently, small disturbance analysis is not possible. This latter point is explored further in Section V.

III. TRAJECTORY DEADLOCK

A. Background

Conceptually, deadlock refers to the situation where a trajectory encounters a condition that precludes further progress. Such behavior is unusual for systems described by continuous dynamics,² though differential-algebraic systems can experience deadlock in the form of algebraic singularity³ [26], [27].

Hybrid dynamical systems, on the other hand, are more prone to deadlock, due to their inherent interactions between continuous dynamics and discrete events. In this context, deadlock has been formally defined in [22]. The form of deadlock of particular relevance to WTG modeling is known as *chattering Zeno*,

²Technically, deadlock cannot occur if the vector field is Lipschitz [25].

³In this case, the term *impasse* is often used rather than deadlock.




Fig. 5. Simplified representation of non-windup limited block and upstream PI controller.

which refers to situations where “the discrete component infinitely jumps instantaneously between different domains, while the continuous component remains unchanged” [22]. Subsequent sections describe this behavior in the context of the type-3 WTG model, and provide an alternative model formulation that alleviates the deadlock phenomenon.

It should be noted that because deadlock precludes continuation of a trajectory, numerical simulation techniques that accurately capture hybrid system dynamics cannot proceed beyond the deadlock point. Conversely, simulators that continue through deadlock cannot be truly implementing the hybrid system model. Special techniques have been developed for continuing approximate solutions beyond deadlock, with Filippov solution concepts forming the basis for those methods [28]. Such concepts are required, for example, in analyzing sliding mode behavior [29]. They are not pursued in this paper.

B. Deadlock in WTG Models

The switching logic that gives rise to trajectory deadlock in the type-3 WTG model can be explained with the aid of the simplified model of Fig. 5. Referring to Fig. 3, it can be seen that this reduced model is equivalent to the output lag block and one of the upstream PI regulators of the WT3P model.

Consider the case where x_1 is on its lower limit x_{\min} , and the input u is negative. According to the non-windup logic of WT3P, the x_2 -integrator would be blocked. Assume that u is increasing, though remains negative. This increase in u will translate directly into an increase in y , as x_2 is constant. With increasing y , conditions conducive to deadlock occur when y reaches the value x_{\min} . This may be explained by noting that $\dot{x}_1 = (y - x_1)/T$, and hence $\dot{x}_1 = 0$ at the point where y equals $x_1 = x_{\min}$. The evolution of x_1 from that point is therefore governed by \ddot{x}_1 , which can be written

$$\ddot{x}_1 = \frac{1}{T}(\dot{y} - \dot{x}_1) = \frac{1}{T}\dot{y} = \frac{1}{T}(\dot{u} + \dot{x}_2).$$

If the x_2 -integrator is blocked, $\dot{x}_2 = 0$, giving $\ddot{x}_1 = (1/T)\dot{u} > 0$ because u is increasing. In this case, x_1 will tend to increase away from the x_{\min} limit, and the x_2 -integrator will become unblocked. On the other hand, if the x_2 -integrator is unblocked, the sign of \ddot{x}_1 is given by $\dot{u} + \dot{x}_2 = \dot{u} + Ku$, which may be negative. If so, x_1 will tend to decrease onto the x_{\min} limit, blocking the x_2 -integrator. A contradiction arises: if the x_2 -integrator is blocked, it should unblock, but if it is unblocked, it should block.




Fig. 6. Large-disturbance response of pitch states.

Returning to the type-3 WTG model, this deadlock phenomenon can be illustrated using the WECC test system and default parameters that are provided in the Appendix. Resulting trajectories are shown in Fig. 6. For the sake of clarity, only the pitch-compensation integrator will be discussed, though the pitch-control integrator exhibits similar behavior. It should be noted that in order to generate the trajectories shown in Fig. 6, it was necessary to introduce hysteresis into the switching process associated with the pitch angle non-windup limit. The implementation of hysteresis is discussed in Section III-C.

The pitch angle θ is initially in steady-state on the lower non-windup limit, where $\theta_0 = \text{PI}_{\min} = 0$ deg. In response to the disturbance, θ undergoes a transient increase, before returning to PI_{\min} at 5.6 s. The error signal $x_{c,\text{err}} = P_{\text{ord}} - P_{\text{set}}$ driving the pitch-compensation integrator is negative at that time, so the corresponding state x_c is frozen. Over the subsequent period, θ and x_c remain frozen, but the signal $\theta_{\text{err}} = \theta_{\text{cmd}} - \theta$, which drives variations in θ , steadily increases until reaching zero⁴ at around 7 s. At that point, θ should transition from blocked to unblocked, so the pitch-compensation integrator driving x_c should also unblock. But notice that $x_{c,\text{err}}$ is negative, so as soon as the integrator unblocks, x_c will decrease, driving θ_{err} negative. This forces θ back onto its PI_{\min} limit, blocking x_c again. But with x_c blocked, θ_{err} increases above zero, and x_c is unblocked. Without hysteresis, this process would repeat *ad infinitum*.

In summary, at the point where θ_{err} encounters zero

- If θ is blocked, then θ and x_c should unblock.
- If θ is unblocked, then θ and x_c should block.

In other words, at the instant when $\theta_{\text{err}} = 0$, the discrete state describing integrator blocking undergoes infinitely many switches, preventing the continuation of the trajectory. This impasse can be circumvented by implementing hysteresis in the blocking/unblocking process, as described in the following section.

⁴The hysteresis implementation actually allows θ_{err} to rise a little beyond zero before the x_c -integrator is unblocked. Further details are provided in Section III-C.




Fig. 7. Expanded view of hysteresis behavior.


It should be mentioned that this example was not concocted to highlight deadlock, but is just the WECC test system with default parameters [15], [16]. Similar behavior has been observed in studies of numerous other systems, suggesting deadlock situations are not uncommon. It should be kept in mind, though, that this is an artifact of the simplified modeling, and is not observed in real WTGs.

C. Implementation of Hysteresis

The explanation of hysteresis will refer to Fig. 7. This is an expanded view of the relevant time interval of Fig. 6. In order to provide a clearer view of behavior, however, the hysteresis band has been widened from 0.002 in Fig. 6 to 0.05 in Fig. 7.

At 6.85 s, the error signal θ_{err} crosses through zero. Upon doing so, the integrator driving the pitch angle θ is unblocked, so θ begins to increase. At 7.3 s, θ encounters the hysteresis threshold, whereupon the pitch-compensation integrator is unblocked. The error signal $x_{c,\text{err}}$ driving that integrator is negative, as shown in Fig. 6, so x_c immediately begins to reduce. This causes θ_{err} to reduce. Eventually θ_{err} goes negative, and θ begins to fall, encountering the non-windup limit $\text{PI}_{\text{min}} = 0$ at 7.6 s. When that limit is encountered, θ and x_c are immediately blocked, so θ_{err} again begins to increase. The process then repeats. The actual implementation of the hysteresis logic is presented in [30].

The width of the hysteresis band ϵ influences behavior during the deadlock period, but has little effect on the subsequent trajectory. This influence was explored using trajectory sensitivities [31]. Fig. 8 shows the sensitivity of the θ and x_c trajectories to a one percent change in the nominal width $\epsilon = 0.002$ of the hysteresis band. It can be seen that the effect of the perturbation in ϵ accumulates over the deadlock period, but subsequently decays very quickly. Choosing a suitable value for ϵ results in a tradeoff between the magnitude of the chatter during the deadlock period versus the number of switching operations.

Fig. 8. Sensitivity of θ and x_c trajectories to a one percent change in the width ϵ of the hysteresis band.

IV. EQUILIBRIUM CONDITIONS

A. Initialization

For the initial point to be in equilibrium, the derivatives in (1)–(3), (5)–(7), and (10) must be set to zero. Notice though that because (2) and (5) are effectively duplicate integrators, they both contribute exactly the same equilibrium equation, $\omega - \omega_{\text{ref}} = 0$. The redundant equation will be ignored when assembling the complete set of initialization equations.

The status of the switched equations must also be consistent with equilibrium conditions. It is safe to assume that none of the limits in the converter control model WT3E would be active during normal steady-state operation. Under that assumption, P_{ord} will equal the electrical power P_{gen} delivered to the WTG terminal bus. This relationship will be used to eliminate P_{gen} from the equilibrium equations.

In the case of the pitch control model WT3P, limits may be active at steady-state. For wind conditions up to rated wind-speed, the pitch angle θ would normally sit at its minimum limit PI_{min} . Blocking the associated integrator would, however, leave the initial value of θ_{cmd} undefined. The initialization process must therefore override integrator blocking, or equivalently, assume θ lies infinitesimally above the PI_{min} limit.

The pitch compensation non-windup limiter of WT3P has the equilibrium characteristic shown in Fig. 9. If the input $P_{\text{ord}} - P_{\text{set}} < 0$ at steady-state, then x_c will be forced to its lower limit of zero. On the other hand, if $P_{\text{ord}} - P_{\text{set}} = 0$ at steady-state, then x_c may take any non-negative value. Summarizing this relationship gives

$$x_c \geq 0, \quad P_{\text{set}} - P_{\text{ord}} \geq 0, \quad x_c(P_{\text{set}} - P_{\text{ord}}) = 0$$

which is a complementarity condition [32], [33] that can be expressed compactly using standard notation

$$0 \leq x_c \perp (P_{\text{set}} - P_{\text{ord}}) \geq 0. \quad (12)$$




Fig. 9. Equilibrium characteristic for the pitch compensation integrator.

The resulting initialization equations can be written

$$0 = f(P_{\text{ord}}) - \omega_{\text{ref}} \quad (13)$$

$$0 = \omega - \omega_{\text{ref}} \quad (14)$$

$$0 = \omega T_{\omega} - P_{\text{ord}} \quad (15)$$

$$0 = P_{\text{mo}} - K_{\text{aero}}\theta(\theta - \theta_o) - P_{\text{mech}} \quad (16)$$

$$0 = P_{\text{mech}} - P_{\text{ord}} \quad (17)$$

$$0 = x_p + x_c + K_{\text{pc}}(P_{\text{ord}} - P_{\text{set}}) - \theta_{\text{cmd}} \quad (18)$$

$$0 = \theta_{\text{cmd}} - \theta \quad (19)$$

together with (12). The dependent state variables are ω_{ref} , T_{ω} , P_{ord} , x_p , x_c , θ , ω , θ_{cmd} , and P_{mech} , while K_{aero} , K_{pc} , P_{mo} , and P_{set} are parameters. By definition, θ_o is the specified initial value for the pitch angle θ , thereby providing a further initialization equation

$$\theta - \theta_o = 0. \quad (20)$$

Because P_{mo} and P_{set} are independent parameters, it is important to consider initialization for the three cases, $P_{\text{mo}} < P_{\text{set}}$, $P_{\text{mo}} = P_{\text{set}}$, and $P_{\text{mo}} > P_{\text{set}}$. To do so, first notice that (16)–(17) and (20) together infer $P_{\text{mo}} = P_{\text{ord}}$ at initialization. Therefore, for the case $P_{\text{mo}} = P_{\text{ord}} < P_{\text{set}}$, the complementarity condition (12), expressed visually in Fig. 9, ensures that $x_c = 0$. In the second case, when $P_{\text{mo}} = P_{\text{ord}} = P_{\text{set}}$, (12) only specifies that $x_c \geq 0$. It follows that the initialization description consists of only eight independent equations describing nine variables. The set of equations is under-determined. This can be confirmed by noting that x_c and x_p appear only in (18), and therefore cannot be uniquely determined. To resolve this situation, (12) should be replaced at initialization by an equation that assigns a specific initial value to x_c or x_p . For consistency with the $P_{\text{mo}} < P_{\text{set}}$ case, it is convenient to replace (12) by

$$x_c = 0. \quad (21)$$

The third case $P_{\text{mo}} = P_{\text{ord}} > P_{\text{set}}$ implies the integrator would be driven by a sustained positive input. The WT3P model does not define an upper limit though, so equilibrium could not be achieved.

B. Post-Disturbance Steady-State

For well-posed dynamical models, the post-disturbance steady-state should match the pre-disturbance (initial) equilibrium when pre- and post-disturbance parameter sets are identical. This is generically not the case for the WECC type-3 WTG model. The following analysis shows that this unusual

behavior is due to switching associated with the duplicate integrators (2) and (5).

The initialization equations (12)–(19) govern post-disturbance steady-state conditions, as they were obtained by setting derivatives to zero. Initialization also made use of the auxiliary equation (20), but that equation plays no role as the system evolves towards steady-state. As a consequence of discarding (20), the description of steady-state conditions is under-determined.

This indeterminacy is resolved when the duplicate integrators (2) and (5) remain unblocked for the entire time horizon. In that case, the integrator states can be written in integral form

$$T_{\omega}(t) = T_{\omega}^o + K_{\text{itrq}} \int_0^t (\omega(\tau) - \omega_{\text{ref}}(\tau)) d\tau \quad (22)$$

$$x_p(t) = x_p^o + K_{\text{ip}} \int_0^t (\omega(\tau) - \omega_{\text{ref}}(\tau)) d\tau \quad (23)$$

where T_{ω}^o and x_p^o are the initial values for the respective states. Equating the integrals in (22) and (23) gives the affine relationship



$$x_p(t) = \frac{K_{\text{ip}}}{K_{\text{itrq}}} T_{\omega}(t) + \left(x_p^o - \frac{K_{\text{ip}} T_{\omega}^o}{K_{\text{itrq}}} \right) \quad (24)$$

which implies that any variation in $T_{\omega}(t)$ will be matched by a corresponding variation in $x_p(t)$. This relationship provides the extra equation required to uniquely determine the post-disturbance steady-state, and in fact implies that if all parameters remain unchanged, the system will evolve to a steady-state that exactly matches the initialization point.

The assumption that the duplicate integrators remain unblocked for all time is seldom true, however. Blocking of one or other of the integrators will alter the corresponding integral term in (22) or (23), invalidating the relationship (24). Under such conditions, it becomes impossible for both T_{ω} and x_p to evolve back to their initial values. Consequently, the system will settle to a post-disturbance steady-state that cannot equal the initial point, even though the parameters of the system are unchanged.

The WECC test system and default parameters of the Appendix illustrate this phenomenon. The pitch angle response of Fig. 6 is repeated in Fig. 10, where the time horizon has been extended to 30 s. Notice that the pitch angle evolves to a steady-state value of 0.33 deg, even though it was initialized at 0 deg.

Fig. 11 shows the relationship between T_{ω} and x_p . These two states initially follow a straight line given by (24), with the states reaching the extreme point $(T_{\omega}, x_p) = (0.847, 0.56)$, before returning along the line to $(0.835, 0.08)$. At that instant, the pitch angle θ encounters its limit, causing the integrator driving x_p to block. The integrator remains blocked until θ enters a period where hysteresis is active. During that period, the x_p -integrator successively blocks and unblocks, giving rise to the staircase phenomenon apparent in the figure. At the end of that period, θ finally comes off its limit, the x_p -integrator is restored to normal operation, and the behavior of T_{ω} and x_p reverts to a straight-line locus given by an affine relationship like (24). The slope over that final section is the same as earlier, but the offset

Fig. 10. Large-disturbance response of pitch angle θ .Fig. 11. Relationship between $T_\omega(t)$ and $x_p(t)$.

has changed. Hence, the system converges to a steady-state that differs from the starting equilibrium point.

As was the case with deadlock, this situation is a consequence of simplified modeling, and does not occur in actual WTGs.

V. SMALL DISTURBANCE ANALYSIS

A. Singularity

Linearizing the WTG (1)–(11) about an equilibrium point, and eliminating the algebraic equations, yields the seventh-order linear model

$$\frac{d}{dt} \begin{bmatrix} \Delta\omega_{\text{ref}} \\ \Delta T_\omega \\ \Delta P_{\text{ord}} \\ \Delta x_p \\ \Delta x_c \\ \Delta\theta \\ \Delta\omega \end{bmatrix} = \begin{bmatrix} a_{11} & \cdot & a_{13} & \cdot & \cdot & \cdot & \cdot \\ a_{21} & \cdot & \cdot & \cdot & \cdot & \cdot & a_{27} \\ a_{31} & a_{32} & a_{33} & \cdot & \cdot & \cdot & a_{37} \\ a_{41} & \cdot & \cdot & \cdot & \cdot & \cdot & a_{47} \\ \cdot & \cdot & a_{53} & \cdot & \cdot & \cdot & \cdot \\ a_{61} & \cdot & a_{63} & a_{64} & a_{65} & a_{66} & a_{67} \\ \cdot & \cdot & a_{73} & \cdot & \cdot & a_{76} & \cdot \end{bmatrix}$$

$$\times \begin{bmatrix} \Delta\omega_{\text{ref}} \\ \Delta T_\omega \\ \Delta P_{\text{ord}} \\ \Delta x_p \\ \Delta x_c \\ \Delta\theta \\ \Delta\omega \end{bmatrix} \quad (25)$$

where the a_{ij} refer to elements of the system A -matrix that are potentially nonzero, while all other elements are identically zero. The exact arrangement of the nonzero a_{ij} is dependent upon the status of limits.

As in Section IV, it is assumed that none of the limits in the converter control model WT3E are enforced at steady-state, and that pitch angle θ dynamics are active. In the case of the pitch compensation x_c -integrator, its dynamics may be active at steady-state or the limiter may be enforced, as indicated in Fig. 9. Both situations must be considered.

The initial value θ_o for the pitch angle also has an important influence on the linear model. When (11) is linearized with $\theta_o = 0$, the term associated with the simplified aerodynamic model becomes zero. In that case, perturbations in the pitch angle θ have no influence on P_{mech} , and as a consequence $a_{76} = 0$ in (25). On the other hand, when $\theta_o \neq 0$, the aerodynamic model contributes a nonzero term to (11), resulting in $a_{76} \neq 0$.

In considering the various cases identified above, it should be kept in mind that (2) and (5) are duplicate integrators. Because these integrators differ only by a scaling factor, the corresponding rows of the A -matrix, 2 and 4, respectively, are linearly dependent. Therefore, A must have at least one eigenvalue whose value is zero.

The two conditions for the x_c -integrator, together with the two possibilities for θ_o , give four separate cases:

1) x_c -Integrator Active, $\theta_o \neq 0$: The condition $\theta_o \neq 0$ implies $a_{76} \neq 0$, so all the a_{ij} shown in (25) are nonzero. The A -matrix has a single zero eigenvalue due to the linear dependence of rows 2 and 4, which correspond to the duplicate integrators. By inspection, columns 4 and 5 are linearly dependent, implying that the right eigenvector associated with the zero eigenvalue involves only Δx_p and Δx_c . Substituting that zero-eigenvector⁵ into (25) gives a matrix-vector product that is zero. Hence, the linear system will be in steady-state at any point along the zero-eigenvector.

2) x_c -Integrator Active, $\theta_o = 0$: In this case, $\theta_o = 0$, so $a_{76} = 0$. By inspection, rows 5 and 7 are linearly dependent, as well as rows 2 and 4, implying the system now has two eigenvalues that are zero. This second zero-eigenvalue is a consequence of pitch angle $\Delta\theta$ being decoupled from mechanical power ΔP_{mech} when $\theta_o = 0$ in the simplified aerodynamic model. With $a_{76} = 0$, columns 4, 5, and 6 are clearly linearly dependent. The two zero-eigenvectors in this case involve Δx_p , Δx_c , and $\Delta\theta$. The linear system will be in steady-state at any point on the plane spanned by the two zero-eigenvectors.

3) x_c -Integrator Blocked, $\theta_o \neq 0$: Blocking the x_c -integrator implies $\Delta x_c \equiv 0$. Accordingly, the fifth row and column of the A -matrix should be removed, reducing the linearized

⁵For convenience, the right eigenvector associated with the zero eigenvalue will be referred to as the zero-eigenvector.




Fig. 12. Standard test system for evaluating WTG dynamic performance.

system to six dynamic states. The linear dependence of rows 2 and 4 is unaffected by this reduction, so one of the eigenvalues remains zero. Because $a_{76} \neq 0$, no simple pairing of columns produces linear dependence. In fact, linear dependence involves all the columns of the reduced A -matrix. Accordingly, the zero-eigenvector includes a contribution from all six states of the reduced model.

4) x_c -Integrator Blocked, $\theta_o = 0$: This case also has $\Delta x_c \equiv 0$, so the A -matrix is again reduced. Because $\theta_o = 0$, the element $a_{76} = 0$, and by inspection the columns corresponding to Δx_p and $\Delta \theta$ are linearly dependent. The zero-eigenvector therefore involves only Δx_p and $\Delta \theta$.

B. Eliminating the Zero Eigenvalue

It is possible to eliminate the zero eigenvalue caused by integrator duplication by exploiting the explicit coupling between integrator states T_w and x_p given by (24). Linearizing that affine relationship gives

$$\Delta x_p(t) = \frac{K_{ip}}{K_{itrq}} \Delta T_w(t). \quad (26)$$

In the linearized model (25), removing the row corresponding to Δx_p , and replacing all occurrences of Δx_p by (26), reduces the system dimension by one. It can be shown that the remaining eigenvalues are exactly the same as the original nonzero eigenvalues. If those original nonzero eigenvalues all have negative real parts, as is generically the case, the system will be exponentially stable.

Even though the linear model has a continuum of equilibria defined by the zero-eigenvector, perturbations that satisfy (26) will induce behavior that returns to the original equilibrium point. On the other hand, perturbations that do not satisfy (26) will result in convergence to points on the zero-eigenvector that generically differ from the original point.

C. Linearizing at Limits

Linearization about an equilibrium point requires the dynamical system to be smooth in a neighborhood of that point. With hybrid dynamical systems, such as the WTG model, equilibria may coincide with conditions that induce switching. In such cases, it is impossible to find a neighborhood of the equilibrium point where the dynamical system is smooth. Linearization is therefore not well defined.

Consider the pitch compensation x_c -integrator, whose equilibrium characteristic is provided in Fig. 9. Linearizing about

an equilibrium point anywhere on the vertical or horizontal sections of the characteristic, away from the transition point at the origin, is well defined and discussed in Section V-A. At the origin, however, switching will occur as perturbations in x_c transition from positive to zero. To establish a linear model at this point, switching must be disabled. The x_c -limit may be ignored, so the origin behaves like a point on the vertical characteristic, or it may be enforced, in which case the origin will act like a point on the horizontal characteristic. It is important to note that the two cases will result in different linear models, and hence eigen-structures that differ. Neither is strictly correct, and results must be interpreted with great care.

A similar discussion applies for the pitch angle θ dynamics. As mentioned in Section IV-A, it is common for θ to be initialized on its lower limit PI_{\min} . A choice must be made whether to treat the integrator as active or blocked. The analysis of Section V-A was based on the assumption that the integrator was active.

The ill-defined nature of linearization at a switching point is particularly important for analysis packages that use finite differences to generate approximate derivatives. Care must be taken to ensure that differences are calculated using perturbations that are physically meaningful. Otherwise, the linear model may be quite inaccurate.

VI. CONCLUSION

The dynamic behavior of type-3 WTGs is governed by interactions between a wound-rotor induction machine and a back-to-back inverter. The inverter response time is much faster than the time constants of the induction machine, allowing the inverter to respond rapidly to the electromechanical dynamics of the WTG. Consequently, the dynamic characteristics of a type-3 WTG that are important from the grid perspective are dominated by the response of controllers that regulate active power, pitch angle, and terminal voltage. These controllers involve interactions between continuous dynamics of state variables and discrete events that occur when limits are encountered. WTGs may therefore be classed as hybrid dynamical systems.

Non-windup limits within the WECC type-3 WTG model have been structured so that various integrators are blocked when a limit is encountered. The interactions inherent in this model structure can be quite complex, and may lead to a form of trajectory deadlock known as chattering Zeno. Deadlock precludes continuation of the trajectory in the normal sense, so numerical simulation techniques that accurately capture hybrid system dynamics cannot proceed beyond such a point. Filippov solution concepts are required for continuing the trajectory. It

TABLE I
IMPEDANCE VALUES FOR THE TEST SYSTEM OF FIG. 12

$R_1 = R_2$	$X_1 = X_2$	$B_1 = B_2$	R_t	X_t
0.025	0.250	0.05	0.0	0.1
R_e	X_e	B_e	R_{te}	X_{te}
0.015	0.025	0.01	0.0	0.05

TABLE II
PARAMETER VALUES FOR WT3G

X_{eq}	K_{pll}	K_{ipll}	P_{lmax}
0.8	30	1	0.1

TABLE III
PARAMETER VALUES FOR WT3E REACTIVE POWER CONTROL

varflg	vltflg	V_{ref}	K_{qi}	V_{max}	V_{min}
0	0	1	0.1	1.1	0.9

TABLE IV
PARAMETER VALUES FOR WT3E ACTIVE POWER (TORQUE) CONTROL

K_{ptrq}	K_{itrq}	T_{pc}	P_{min}	P_{max}	I_{pmax}	dP_{max}/dt	T_{sp}
3	0.6	0.05	0.04	1.12	1.1	0.45	5

TABLE V
PARAMETER VALUES FOR SPEED-POWER CURVE $f(P_{gen})$

ω_{pmin}	ω_{p20}	ω_{p40}	ω_{p60}	$P_{\omega p100}$	ω_{p100}
0.69	0.78	0.98	1.12	0.74	1.2

TABLE VI
PARAMETER VALUES FOR WT3T SINGLE-SHAFT MODEL

K_{aero}	θ_0	P_{m0}	H	D
0.007	0	1	4.94	0

TABLE VII
PARAMETER VALUES FOR WT3P

K_{pp}	K_{ip}	K_{pc}	K_{ic}	T_{PI}	PI_{max}	PI_{min}	PI_{rate}	P_{set}
150	25	3	30	0.3	27	0	10	1

has been shown that deadlock can be eliminated by incorporating hysteresis into the switching of non-windup limits.

The converter controller and the pitch controller of the WECC type-3 WTG model both include an integrator that is driven by the same frequency error signal. This integrator duplication results in an under-determined description of steady-state conditions, allowing the existence of a continuum of equilibria. As a consequence, power systems that incorporate WTGs may converge to a post-disturbance steady-state that does not match initial conditions, even though the parameter set has not changed. Furthermore, the duplicate integrators result in linearly dependent rows in the linearized WTG model, so the system is singular. Small disturbance analysis of power systems with WTGs will yield at least one zero-eigenvalue for every WTG.

APPENDIX

WECC DEFAULT PARAMETER VALUES

The test system is given in Fig. 12. Parameter values are given in Tables I–VII. The wind generator output is $100 \text{ MW} =$

1.0 pu . A 10-MVAr capacitor is connected at bus 3, but no shunt is connected at bus 5.

A three-phase fault is applied at bus 2 at 1 s. It is cleared at 1.15 s by disconnecting one of the 230-kV transmission lines.

REFERENCES

- [1] T. Ackermann, Ed., *Wind Power in Power Systems*. Chichester, U.K.: Wiley, 2005.
- [2] E. Muljadi, C. Butterfield, B. Parsons, and A. Ellis, "Effect of variable speed wind turbine generator on stability of a weak grid," *IEEE Trans. Energy Convers.*, vol. 22, no. 1, pp. 29–36, Mar. 2007.
- [3] D. Gautam, V. Vittal, and T. Harbour, "Impact of increased penetration of DFIG-based wind turbine generators on transient and small signal stability of power systems," *IEEE Trans. Power Syst.*, vol. 24, no. 3, pp. 1426–1434, Aug. 2009.
- [4] M. Nunes, J. Lopes, H. Zurn, U. Bezerra, and R. Almeida, "Influence of the variable-speed wind generators in transient stability margin of the conventional generators integrated in electrical grids," *IEEE Trans. Energy Convers.*, vol. 19, no. 4, pp. 692–701, Dec. 2004.
- [5] N. Ullah and T. Thiringer, "Effect of operational modes of a wind farm on the transient stability of nearby generators and on power oscillations: A Nordic grid study," *Wind Energy*, vol. 11, pp. 63–73, Sept. 2007.
- [6] D. Kosterev and D. Davies, "System model validation studies in WECC," in *Proc. IEEE PES General Meeting*, Minneapolis, MN, Jul. 2010.
- [7] I. Hiskens and J. Alseddiqui, "Sensitivity, approximation and uncertainty in power system dynamic simulation," *IEEE Trans. Power Syst.*, vol. 21, no. 4, pp. 1808–1820, Nov. 2006.
- [8] J. Slootweg, S. de Haan, H. Polinder, and W. Kling, "General model for representing variable speed wind turbines in power system dynamics simulations," *IEEE Trans. Power Syst.*, vol. 18, no. 1, pp. 144–151, Feb. 2003.
- [9] J. Ekanayake, L. Holdsworth, X.-G. Wu, and N. Jenkins, "Dynamic modeling of doubly fed induction generator wind turbines," *IEEE Trans. Power Syst.*, vol. 18, no. 2, pp. 803–809, May 2003.
- [10] Y. Lei, A. Mullane, G. Lightbody, and R. Yacamini, "Modeling of the wind turbine with a doubly fed induction generator for grid integration studies," *IEEE Trans. Energy Convers.*, vol. 21, no. 1, pp. 257–264, Mar. 2006.
- [11] M. Kayikçi and J. Milanović, "Assessing transient response of DFIG-based wind plants—The influence of model simplifications and parameters," *IEEE Trans. Power Syst.*, vol. 23, no. 2, pp. 545–554, May 2008.
- [12] J. Rose and I. Hiskens, "Estimating wind turbine parameters and quantifying their effects on dynamic behavior," in *Proc. IEEE PES General Meeting*, Pittsburgh, PA, Jul. 2008.
- [13] K. Clark, N. Miller, and J. Sanchez-Gasca, "Modeling of GE wind turbine-generators for grid studies," Version 4.4, GE Energy, Sep. 2009.
- [14] E. Muljadi, C. Butterfield, J. Conto, and K. Donoho, "ERCOT's dynamic model of wind turbine generators," in *Proc. WindPower 2005*, Denver, CO, May 2005.
- [15] Generic Type-3 Wind Turbine-Generator Model for Grid Studies, Version 1.1, WECC Wind Generator Modeling Group, Sep. 2006.
- [16] WECC Wind Power Plant Dynamic Modeling Guide, WECC Renewable Energy Modeling Task Force, Nov. 2010.
- [17] Z. Lubosny, *Wind Turbine Operation in Electric Power Systems*. New York: Springer, 2003.
- [18] A. van der Schaft and H. Schumacher, *An Introduction to Hybrid Dynamical Systems*. London, U.K.: Springer-Verlag, 2000.
- [19] D. Liberzon, *Switching in Systems and Control*. Boston, MA: Birkhauser, 2003.
- [20] I. Hiskens, "Power system modeling for inverse problems," *IEEE Trans. Circuits Syst. I, Reg. Papers*, vol. 51, no. 3, pp. 539–551, Mar. 2004.
- [21] *IEEE Recommended Practice for Excitation System Models for Power System Stability Studies*, IEEE Std. 421.5-2005, 2005.
- [22] A. Abate, A. D'Innocenzo, M. Di Benedetto, and S. Sastry, "Understanding deadlock and livelock behaviors in hybrid control systems," *Nonlin. Anal.: Hybrid Syst.*, vol. 3, no. 2, pp. 150–162, May 2009.
- [23] I. Hiskens, Dynamics of Type-3 Wind Turbine Generator Models, Dept. Elect. Eng. Comput. Sci., Univ. Michigan, Tech. Rep., Dec. 2010.
- [24] I. Hiskens and P. Sokolowski, "Systematic modeling and symbolically assisted simulation of power systems," *IEEE Trans. Power Syst.*, vol. 16, no. 2, pp. 229–234, May 2001.

- [25] H. Khalil, *Nonlinear Systems*, 3rd ed. Upper Saddle River, NJ: Prentice-Hall, 2001.
- [26] I. Hiskens and D. Hill, "Energy functions, transient stability and voltage behaviour in power systems with nonlinear loads," *IEEE Trans. Power Syst.*, vol. 4, no. 4, pp. 1525–1533, Nov. 1989.
- [27] V. Venkatasubramanian, H. Schättler, and J. Zaborszky, "Dynamics of large constrained nonlinear systems—A taxonomy theory," *Proc. IEEE*, vol. 83, no. 11, pp. 1530–1561, Nov. 1995.
- [28] A. Filippov, *Differential Equations With Discontinuous Righthand Sides*. Dordrecht, The Netherlands: Kluwer, 1988.
- [29] V. Utkin, J. Guldner, and J. Shi, *Sliding Mode Control in Electro-Mechanical Systems*, 2nd ed. Boca Raton, FL: CRC, 2009.
- [30] I. Hiskens, "Trajectory deadlock in power system models," in *Proc. IEEE Int. Symp. Circuits and Systems*, Rio de Janeiro, Brazil, May 2011, pp. 2721–2724.
- [31] I. Hiskens and M. Pai, "Trajectory sensitivity analysis of hybrid systems," *IEEE Trans. Circuits Syst. I, Fundam. Theory Appl.*, vol. 47, no. 2, pp. 204–220, Feb. 2000.
- [32] R. Cottle, J.-S. Pang, and R. Stone, *The Linear Complementarity Problem*. Boston, MA: Academic, 1992.
- [33] A. van der Schaft and J. Schumacher, "Complementarity modeling of hybrid systems," *IEEE Trans. Autom. Control*, vol. 43, no. 4, pp. 483–490, Apr. 1998.



Ian A. Hiskens (S'77–M'80–SM'96–F'06) received the B.Eng. degree in electrical engineering and the B.App.Sc. degree in mathematics from the Capricornia Institute of Advanced Education, Rockhampton, Australia, in 1980 and 1983, respectively and the Ph.D. degree in electrical engineering from the University of Newcastle, Newcastle, Australia, in 1991.

He is the Vennema Professor of Engineering in the Department of Electrical Engineering and Computer Science, University of Michigan, Ann Arbor. He has

held prior appointments in the Queensland electricity supply industry, and various universities in Australia and the United States. His major research interests lie in the area of power system analysis, in particular system dynamics and control, and security assessment. His recent activity has focused largely on integration of renewable generation and controllable load.

Dr. Hiskens is actively involved in various IEEE societies, and is Treasurer of the IEEE Systems Council. He is an Editor of the IEEE TRANSACTIONS ON POWER SYSTEMS, and past Editor of the IEEE TRANSACTIONS ON CONTROL SYSTEMS TECHNOLOGY and the IEEE TRANSACTIONS ON CIRCUITS AND SYSTEMS. He is a Fellow of Engineers Australia and a Chartered Professional Engineer in Australia.